

ROUND PATTERN CALIBRATION PROGRAM

PAGE 01 of 01
DATE 10-19-03
TIME 16:43:09

THEORETICAL CALIBRATION FOR
SERIAL NUMBER OMV834701-15
MODEL NUMBER TEA-F2-R 5000X1
CAPACITY OF COMPARTMENT ONE

5,000 NOMINAL GALLONS + 0.00%
5,000 GALLONS SHELL FULL

- NOTES: 1. CAPACITY IN U.S GALLONS - TANK ASSUMED LEVEL.
2. CALIBRATION COMPUTED MATHEMATICALLY - NOT LEGAL FOR TRADE.
3. FLUID CAPACITY OF PIPING NOT INCLUDED.

DEPTH	.00	.25	.50	.75	DEPTH	.00	.25	.50	.75
--- U.S. GALLONS ---					--- U.S. GALLONS ---				
0 IN	0	2	7	13	1 IN	20	28	36	46
2 IN	56	67	78	90	3 IN	102	115	129	143
4 IN	157	172	187	202	5 IN	218	235	251	268
6 IN	286	303	321	340	7 IN	358	377	396	416
8 IN	435	455	476	496	9 IN	517	538	559	581
10 IN	602	624	646	669	11 IN	691	714	737	760
12 IN	783	807	830	854	13 IN	878	902	927	951
14 IN	976	1000	1025	1051	15 IN	1076	1101	1127	1152
16 IN	1178	1204	1230	1256	17 IN	1282	1309	1335	1362
18 IN	1388	1415	1442	1469	19 IN	1496	1523	1551	1578
20 IN	1605	1633	1661	1688	21 IN	1716	1744	1772	1800
22 IN	1828	1856	1884	1912	23 IN	1940	1968	1997	2025
24 IN	2053	2082	2110	2139	25 IN	2167	2196	2225	2253
26 IN	2282	2311	2339	2368	27 IN	2397	2425	2454	2483
28 IN	2512	2540	2569	2598	29 IN	2627	2655	2684	2713
30 IN	2741	2770	2799	2827	31 IN	2856	2885	2913	2942
32 IN	2970	2999	3027	3055	33 IN	3084	3112	3140	3168
34 IN	3197	3225	3253	3281	35 IN	3308	3336	3364	3392
36 IN	3419	3447	3474	3502	37 IN	3529	3556	3583	3610
38 IN	3637	3664	3691	3717	39 IN	3744	3770	3797	3823
40 IN	3849	3875	3901	3926	41 IN	3952	3977	4002	4028
42 IN	4053	4077	4102	4127	43 IN	4151	4175	4199	4223
44 IN	4247	4270	4294	4317	45 IN	4340	4363	4385	4408
46 IN	4430	4452	4474	4495	47 IN	4516	4537	4558	4579
48 IN	4599	4619	4639	4658	49 IN	4678	4697	4715	4734
50 IN	4752	4770	4787	4804	51 IN	4821	4837	4853	4869
52 IN	4884	4899	4914	4928	53 IN	4941	4954	4967	4979
54 IN	4991	5002	5012	5021	55 IN	5030	5039	5046	5052
56 IN	5057	5060							